WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42834
Permit No.
Basin 4-49

NOTICE OF INTENT NO. 23946

1. OWNER ALAN DUEWEL
MAILING ADDRESS 350 West Fir Street
Elko, NV 89801
ADDRESS AT WELL LOCATION Royal Crest Drive

2. LOCATION NE ¼ NW ¼ Sec. 17 T 34 N/S R 55 E Elko County
PERMIT NO. (Issued by Water Resources) 6-09F-62 (Parcel No.) Special lands (Subdivision Name)

3. WORK PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[x] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [x] Rotary [ ] RVC
[x] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	3	3
Sand boulders		3	13	10
Brown siltstone some boulder mix		13	21	8
Red sandstone		21	85	64
Brown siltstone some boulder mix		85	360	275

'93 OCT 13 A11:49
STATE ENGINEER

Date started September 29, 1993
Date completed September 30, 1993

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [x] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50		4

8. WELL CONSTRUCTION
Depth Drilled 360 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10-5/8 Inches	0 Feet	360 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	+1-1/2	360

Perforations:
Type perforation Mill slot
Size perforation 3/16 x 3
From 340 feet to 360 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [x] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [x] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [x] Concrete Grout

Gravel Packed: [x] Yes [ ] No
From 50 feet to 360 feet

9. WATER LEVEL
Static water level 200 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed David Hersh (By driller performing actual drilling on site or contractor)
Date 10-7-1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627