WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42835
Permit No.
Basin 4-49

NOTICE OF INTENT NO. 24248

1. OWNER JACK SHIPP
MAILING ADDRESS 505 Copper St. Apt. 1107 Elko, NV 89801
ADDRESS AT WELL LOCATION north side of 33rd street between Owyhee Ave. and Yosemite Avenue

2. LOCATION NE ¼ NE ¼ Sec. 31 T. 34 N/S R. 55 E. Elko County
PERMIT NO. (Issued by Water Resources) 64-001-10 (Parcel No.) Meadow Valley Rancho #9 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay		0	10	10
Sand gravel		10	35	25
Blue clay		35	85	50
Brown siltstone		85	135	50
Blue clay		135	140	5

'93 OCT 13 AM 11:49
STATE ENGINEER'S OFFICE

Date started September 24, 1993
Date completed September 27, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100		4

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10-5/8 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	1-1/2	140

Perforations:
Type perforation Mill slot
Size perforation 3/16 x 3
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 30 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P.O. Box 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 10-7-1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627