

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 42841  
 Permit No. \_\_\_\_\_  
 Basin 4-49

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22253

1. OWNER SCOTT INMAN ADDRESS AT WELL LOCATION CORNER of Centen  
ELKO NV street and pitue  
 MAILING ADDRESS 1050 CONNLY # 115  
 2. LOCATION NE 1/4 SW 1/4 Sec. 3 T. 35 N/S R 56 E ELKO County  
 PERMIT NO. 35-022-01-1 Parcel No. Meadow Valley Randome Subdivision Name OSCAN  
 Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Loam		0	2	2
Hard pan		02	34	32
CLAY		34	138	104
SAND Gravel	X	138	150	12

8. WELL CONSTRUCTION  
 Depth Drilled 150 Feet Depth Cased 150 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 6 Inches To 180 Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	1.88	0	150

Perforations:  
 Type perforation slots  
 Size perforation 3/16 x 3  
 From 130 feet to 150 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 55  
 Placement Method:  Pumped  
 Poured  
 Gravel Packed:  Yes  No  
 From 55 feet to 150 feet

9. WATER LEVEL  
 Static water level 29 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality Good

Date started 9-27 1993  
 Date completed 9-28 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>40-60</u>		<u>2</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Fertig Drilling Co Contractor  
 Address PO Box 525 Contractor  
ELKO NV 89803  
 Nevada contractor's license number 31904  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584  
 Signed Michael Fertig  
 By driller performing actual drilling on site or contractor  
 Date 10-13-93