

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY  
 Log No. 412865  
 Permit No. 4-5A  
 Basin 4-5A

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 24078  
 ADDRESS AT WELL LOCATION Millard Fillmore Rd.

1. OWNER Harry Stowe  
 MAILING ADDRESS 1740 Presidential Blvd.  
119-3 Bt., Mt., Nv. 89820

ADDRESS AT WELL LOCATION Millard Fillmore Rd.

2. LOCATION SW 1/4 NE 1/4 Sec 9 T 31N N/S R 45E E Lander County  
 PERMIT NO. 8-800-20 Parcel No. N/A Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

| Material                             | Water Strata | From | To | Thick-ness |
|--------------------------------------|--------------|------|----|------------|
| Soil Brown                           |              | 0    | 1  | 1          |
| Clay Brown                           |              | 1    | 4  | 3          |
| Course Sand+Gravel                   |              |      |    |            |
| Brown                                |              | 4    | 36 | 32         |
| Sand Brown Cemented                  |              | 36   | 44 | 8          |
| Clay Brown                           |              | 44   | 58 | 14         |
| Clay Brown with strips of Sand+Shale | 17           | 58   | 75 |            |

8. WELL CONSTRUCTION  
 Depth Drilled 75 Feet Depth Cased 75 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 50 Feet  
6 Inches 50 Feet 75 Feet  
 Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6                  | 14                  | .188                    | 0           | 61        |
| 5-9/16             | 8                   | .134                    | 54          | 75        |

Perforations:  
 Type perforation Torch  
 Size perforation 1/8" by 5" 75  
 From 51 feet to 75 feet  
 From        feet to        feet  
 From        feet to        feet  
 From        feet to        feet  
 From        feet to        feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From        feet to        feet

9. WATER LEVEL  
 Static water level 10 feet below land surface  
 Artesian flow        G.P.M. P.S.I.  
 Water temperature 54 °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name T + R DRILLING  
 Address P. O. Box 1982 Wmca., Nv. 89446  
 Nevada contractor's license number 017721  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1190  
 Division of Water Resources, the on-site driller  
 Signed Thomas Stt  
 By driller performing actual drilling on site or contractor  
 Date 10-19-93

Date started 10-11-1993  
 Date completed 10-13-1993

7. WELL TEST DATA

| TEST METHOD: <input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift |                               |              |  |
|-------------------------------------------------------------------------------------------------------------------------|-------------------------------|--------------|--|
| G.P.M.                                                                                                                  | Draw Down (Feet Below Static) | Time (Hours) |  |
| <u>30</u>                                                                                                               | <u>10</u>                     | <u>2 1/2</u> |  |

NOV 16 10:47  
 RECEIVED  
 STATE ENGINEERS OFFICE