SPL-90-B

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42880
Permit No.
Basin 4-61

NOTICE OF INTENT NO. 14983

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

ADDRESS AT WELL LOCATION BARRICK GOLDSTRIKE MINE

2. LOCATION SE ¼ SE ¼ Sec. 30 T. 36 (N/S) R. 50 E. EUREKA County
PERMIT NO. WANER M/O-255 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
WELL CASING WAS SEALED AT THE SURFACE, SO				
IT WAS NOT PULLED. CASING WAS NOT				
RIPPED DUE TO SLOTS ALREADY IN CASING.				
PUMPED NEAT CEMENT FROM 379 FT. TO SURFACE.				

'93 SEP 29 A11:10
STATE ENGINEER'S OFFICE

Date started SEPTEMBER 9, 19 93
Date completed SEPTEMBER 9, 19 93

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 405 Feet Depth Cased 379 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
14 Inches	0 Feet	20 Feet	
10 Inches	20 Feet	405 Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10		.250	0	20
4		SCH. 40	+ 1	269
4		SCH. 40	369	379

Perforations:
Type perforation SLOTTED
Size perforation
From 269 feet to 369 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 255 feet to 405 feet

9. WATER LEVEL
Static water level NONE feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UT 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1773
Signed Mark Waite MARK WAITE
(By driller performing actual drilling on site or contractor)
Date SEPTEMBER 22, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627