WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 42882
Permit No.
Basin 21-51

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 24944

1. OWNER Newmont Gold Corp
MAILING ADDRESS PO Box 669
Carlin NEVADA 89822
ADDRESS AT WELL LOCATION Genesis Pit
GNTW-14

2. LOCATION NE ¼ SE ¼ Sec 31 T 36 N/S R 50 E Eureka County
PERMIT NO. 5660 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☑ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
altered siltstone		0	160	160
altered siltstone	yes	160	320	160
clay		320	370	50
altered siltstone	yes	370	720	350
clay		720	800	80
altered siltstone	yes	800	900	100
clay altered volcanic		900	1000	100

'93 NOV 19 AM 10:37 STATE ENGINEER'S OFFICE

Date started 10/4, 1993
Date completed 10/19, 1993

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
air lift	≈ 80		

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 15 inches 20 Total depth 1000 feet
12 5/8 inches 920'
8 5/8 inches 1000'
Casing record 8 5/8"
Weight per foot 32 Thickness 1/4"

Diameter	From	To
8 5/8 inches	0 feet	872.5 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Neat cement
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 872.5 feet

Perforations:
Type perforation milled slot
Size perforation 18
From 72'5" feet to 288 feet
From 460 feet to 686.5 feet
From 767.5 feet to 867.5 feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level ≈ 160 feet below land surface
Flow No G.P.M. No P.S.I.
Water temperature 55 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Austin Corp (Contractor)
Address PO Box 894 Elko NV 89803 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0022193
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1673
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 11/8/93

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627