

OFFICE USE ONLY  
 Log No. 42911  
 Permit No. 6-83  
 Basin 6-83  
 NOTICE OF INTENT NO. 23792

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Paul Dyer ADDRESS AT WELL LOCATION 1771 Harte  
 MAILING ADDRESS P. O. Box 969 1771 Harte  
Virginia City, Nv 89440 Lot 103, 104, and 105 / Lot 106 Bk M  
 2. LOCATION NE 1/4 NE 1/4 Sec 5 T. 17 N/S R. 21 E. Storey County Storey  
 PERMIT NO. 3-131-12 Virginia City Highlands  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Volcanic sands with broken volcanic cobbles red brown green yellow		0	4	4
purple white volcanic rock with some clay & volcanic sands	2	4	11	7
Light green & purple volcanic rock	60	11	114	103
T.D. 114 ft				

'93 OCT 14 AM 41  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 114 Feet Depth Cased 114 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 55 Feet  
8 1/2 Inches 55 Feet 114 Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	1292	.188	+ 2	114

Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3  
 From 80 feet to 100 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 114 feet

9. WATER LEVEL  
 Static water level 51 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality \_\_\_\_\_

Date started 9/28/93, 19\_\_\_\_  
 Date completed 9/29/93, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	20+		2

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling & Well Service, Inc Contractor  
 Address 625 Spice Islands Dr Suite L  
Sparks, Nv 89431 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 15291  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511  
 Signed Roger M. Thrall  
 By driller performing actual drilling on site or contractor  
 Date Roger M. Thrall 9/30/93