

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 42974  
 Permit No. 6-831  
 Basin. 1  
 NOTICE OF INTENT NO. 23793

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Ivan Pitmon ADDRESS AT WELL LOCATION 41470 Graves Rd  
 MAILING ADDRESS 530 East Patriot Dr # 246 Reno, Nv 89511 Lot 36 Block U  
 2. LOCATION SE 1/4 NW 1/4 Sec. 8 T. 17 N/S R. 21 E Storey County Virginia City Highlands  
 PERMIT NO. 03-182-15 - Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Yellow green clay with some volcanic rock		0	25	25
Light green & reddish brown volcanic rock with traces of yellow clay		25	83	58
Light green & gray volcanic rock with gray clay		83	142	59
Gray & green volcanic rock	352	142	410	268
Light green & black volcanic rock		410	450	40
T.D. 450 ft				

8. WELL CONSTRUCTION  
 Depth Drilled 450 Feet Depth Cased 450 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 61 Feet  
8 1/2 Inches 61 Feet 450 Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	450

Perforations:  
 Type perforation factory sawed  
 Size perforation 3/32 x 3  
 From 410 feet to 430 feet  
 From 350 feet to 370 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 51  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 51 feet to 450 feet

9. WATER LEVEL  
 Static water level 180 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name AQUA DRILLING & WELL SERVICE, INC  
 Address 625 SPICE ISLANDS DR SUITE L  
SPARKS, NV 89431  
 Nevada contractor's license number 15291  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1511  
 Division of Water Resources, the on-site driller  
 Signed Roger M. Thrall  
 By Driller performing actual drilling on site or contractor  
 Date 10/5/93

Date started 9/29/93, 19\_\_\_\_  
 Date completed 10/4/93, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15</u>	<u>3</u>	<u>3</u>