

OFFICE USE ONLY  
 Log No. 42920  
 Permit No. \_\_\_\_\_  
 Basin 6-84

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23800

1. OWNER Double P Farms / Tom Pratt ADDRESS AT WELL LOCATION 5800 Whiskey Springs Rd  
 MAILING ADDRESS 100 Grove Reno, Nv 89509 Parcel # 3  
 2. LOCATION NE 1/4 SW 1/4 Sec. 5 T. 22 N. 21 E. Washoe County  
 PERMIT NO. 77-090-03 Subdivision Name \_\_\_\_\_  
 Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Green brown yellow				
white red coarse sands & gravels		172	397	225
T.D. 397 ft				

93 OCT 12 AM 10:12  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 397 Feet Depth Cased 397 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 172 To 300  
7 7/8 Inches Feet Feet  
 From 280 To 397  
6 1/4 Inches Feet Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	- 2	280
5	9.66	.188	257	397

Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3  
 From 357 feet to 397 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal refer to original log  Neat Cement  
 Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 130 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality \_\_\_\_\_

Date started 8/25/93, 19\_\_\_\_\_  
 Date completed 8/30/93, 19\_\_\_\_\_  
 7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
18		3

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling & Well Service, Inc  
 Contractor  
 Address 625 Spice Islands Dr Suite L Sparks, Nv 89431  
 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 15291  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511  
 Signed Roger M Thrall  
 By driller performing actual drilling on site of contractor  
 Date Roger M. Thrall 9/2/93