

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23869

1. OWNER David & Lisa Tauchen ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 50 Ryerson Ct 650 Curnow Canyon Rd
Sparks, nv 89436 32-2-1-8
 2. LOCATION NE 1/4 SW 1/4 Sec. 32 T. 22 N/S R. 21 E Washoe County _____
 PERMIT NO. 76-180-15 - Palomino Valley Unit 4
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE
 New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other _____ Municipal/Industrial Monitor Stock Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Tan yellow white brown D.G. sands with traces of tan clay		0	16	16
Semi decomposed granite tan brown white		16	38	22
White black & tan granite [hard]		38	457	419
Light green blue white & tan granite	545	457	605	148
T.D. 605 ft				

8. WELL CONSTRUCTION
 Depth Drilled 605 Feet Depth Cased 605 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 58 Feet
8 Inches 58 Feet 605 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 2	605

Perforations: factory
 Type perforation _____
 Size perforation 3/32 X 3
 From 577 feet to 597 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: _____
 Depth of Seal 54 Neat Cement
 Placement Method: Pumped Poured Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From 54 feet to 605 feet

9. WATER LEVEL
 Static water level 510 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
 Address 625 Spice Islands Dr Suite L
Sparks, Nv 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1511
 Division of Water Resources, the on-site driller
 Signed Roger M Thrall
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 10/

Date started 10/21/93, 19_____
 Date completed 10/28/93, 19_____
 7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20+</u>		<u>1 1/2</u>

'93 NOV -9 AND :46
 STATE ENGINEERS OFFICE