

OFFICIAL USE ONLY  
Log No. 42920  
Permit No. 86  
Basin I  
NOTICE OF INTENT NO. 25061

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Reno Sparks Tongan Wesleyan Methodist Church ADDRESS AT WELL LOCATION  
MAILING ADDRESS W. 7th & Billen Lane W. 7th & Billen Lane  
Sun Valley, NV Sun Valley, NV

2. LOCATION SW 1/4 NW 1/4 Sec 13 T. 20 N/S R 19 E Washoe County  
PERMIT NO. 54679/Waiver 71535 008-210-26 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Hard Granite		175	180	5
Broken Granite	X	180	200	20
Blue Granite		200	205	5
Checked Well and it is 175 ft. deep with 6 5/8" well .188" wall.				
Has Cement Seal/Well Pumped 4GPM				
Tag on well was drilled by Barrows in 1978				

8. WELL CONSTRUCTION  
Depth Drilled 30 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)  
From 6 1/2 Inches 175 Feet 205 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>5 9/16</u>		<u>.188</u>	<u>165</u>	<u>205</u>

Perforations:  
Type perforation Mill Cut  
Size perforation 1/8"  
From 165 feet to 205 feet  
From feet to feet  
From feet to feet  
From feet to feet  
From feet to feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal \_\_\_\_\_  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From feet to feet

9. WATER LEVEL  
Static water level 80 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cool °F Quality unknown

Date started 11-18- 19 93  
Date completed 11-18 19 93

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25</u>		<u>2 Hours</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Parsons Drilling, Inc. Contractor  
Address P.O. Box 1265 Contractor  
Fallon, NV 89407-1265  
Nevada contractor's license number 29064 issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454  
Signed Thomas Parsons  
By driller performing actual drilling on site or contractor  
Date 11-19-93