WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42931
Permit No.
Basin 6-87

NOTICE OF INTENT NO. 23267

1. OWNER Antonio Maruri
MAILING ADDRESS 15490 Fawn Lane
Reno, Nevada 89511

ADDRESS AT WELL LOCATION
SAME

2. LOCATION SW ¼ NW ¼ Sec. 36 T. 18 ☒ S R. 19 ☐ E Washoe County
PERMIT NO. N/A (Issued by Water Resources) | 049-122-02 (Parcel No.) | None (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| D.G. & Granite | XX | 120 | 220 | 100 |

'93 SEP 27 A11:48
STATE ENGINEER'S OFFICE

Date started 9-9-93, 19
Date completed 9-10-93, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| Approx. | 15 | 200 | 3 |

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 6 Inches | | 120 Feet | 220 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 5 9/16 | 15 | .258 | 110 | 220 |

Perforations:
Type perforation Mill Slot
Size perforation 1/8 X 3
From 110 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 105 feet below land surface
Artesian flow None G.P.M. None P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EMDLCO (Contractor)
Address P.O. Box 8056 (Contractor)
Reno, Nevada 89507
Nevada contractor's license number issued by the State Contractor's Board 32166-C23
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418
Signed Bruce Miller (By driller performing actual drilling on site or contractor)
Date 9-17-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627