

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **23782**

1. OWNER Cary Olson ADDRESS AT WELL LOCATION 1400 Monte Vista Dr  
 MAILING ADDRESS P. O. Box 23 Lot 13 and 2 Block D  
Gardnerville, Nv 89410  
 2. LOCATION SE  $\frac{1}{4}$  SW  $\frac{1}{4}$  Sec. 7 T. 18 N/S R. 20 E. Washoe County  
 PERMIT NO. 44-363-06 - Sierra Manor  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown tan white D.G. with cobbles & boulders		0	17	17
Red brown yellow orange purple volcanic sands & gravels		17	108	91
Same sands with tan clay		108	127	19
Red & green volcanic rock fractured		127	178	51
T.D. 178 ft				

8. WELL CONSTRUCTION  
 Depth Drilled 178 Feet Depth Cased 178 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 To 58  
10 5/8 Inches Feet  
8 1/2 Inches 58 Feet 178 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 2	178

Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3  
 From 158 feet to 178 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 52  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 52 feet to 178 feet

9. WATER LEVEL  
 Static water level 22 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling & Well Service, Inc  
 Contractor  
 Address 625 Spice Islands Dr Suite L  
 Contractor  
Sparks, Nv 89431  
 Nevada contractor's license number 15291  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1511  
 Division of Water Resources, the on-site driller  
 Signed Roger M Thrall  
 By driller performing actual drilling on site or contractor  
 Date Roger M. Thrall 8/17/93

Date started 8/12/93, 19\_\_\_\_\_  
 Date completed 8/13/93, 19\_\_\_\_\_  
 7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		1 3/4

'93 OCT 12 AM 12  
 STATE ENGINEERS OFFICE