WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

(916) 852-6590

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42938
Permit No.
Basin Co-87

NOTICE OF INTENT NO. 20196

1. OWNER EXXON c/o Alton Geoscience
MAILING ADDRESS 3035 Prospect Park Dr., #80 Rancho Cordova, CA 95670
ADDRESS AT WELL LOCATION 4th & Virginia RENO, NEVADA

2. LOCATION SW ¼ NE ¼ Sec. 11 T. 19 N/S R. 19 E. County
PERMIT NO. MW-118 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ ~~Replace~~ ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. ~~PROPOSED~~ USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Gravel				
MW-4				
WELL Abandonment Details:				
Mixture: 6 gals of H2O per sack of Cement.				
No. of sacks used: 7				
Method: Pressure Grout				
Reason for Method: Pressure grouting used to avoid the possibility of losing Auger due to the type of geology.				

Date started 2-4, 19 92
Date completed 2-4, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 50 Feet Depth Cased 50 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
8"	0	50

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2-1/4	—	0.25"	0	50

Perforations:
Type perforation Slots
Size perforation 0.020"
From 25 feet to 50 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50' to Surface
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level ~38 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name West Hazmat Drilling Contractor
Address 3233 Fitzgerald Road Contractor
Rancho Cordova, CA 95742
Nevada contractor's license number issued by the State Contractor's Board 31386
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1723
Signed Bruce Niemayer By driller performing actual drilling on site or contractor
Date 2-17-92

STATE ENGINEERS OFFICE
'92 MAR 25 AM 11:17

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627