


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**



OFFICE USE ONLY  
 Log No. 42958

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12094

1. OWNER CACTUS SPRINGS ADDRESS AT WELL LOCATION CACTUS SPRINGS TRUCK STOP  
 MAILING ADDRESS SANDSTONE LAND & CATTLE COMPANY 99997 TONOPAH HIGHWAY U.S. 95  
2140 OUTPOST DRIVE, HOLLYWOOD, CA 90068 CACTUS SPRINGS, NEVADA  
 2. LOCATION NE 1/4 NE 1/4 Sec 11 T 16 N R 55 E CLARK County  
 PERMIT NO. MO-2310 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SILTY SAND</u>		<u>0</u>	<u>7</u>	<u>7</u>
<u>CLAYEY SAND</u>		<u>7</u>	<u>10</u>	<u>3</u>
<u>SILTY CLAY</u>		<u>10</u>	<u>25</u>	<u>15</u>
<u>TD = 25.0</u>				

8. WELL CONSTRUCTION  
 Depth Drilled 25 Feet Depth Cased 25 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8 Inches 0 Feet 25 Feet  
 To \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>0.7</u>	<u>Sch 40</u>	<u>0</u>	<u>25</u>

Perforations:  
 Type perforation FACTORY SCOTTED  
 Size perforation 0.01"  
 From 5 feet to 25 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 0-3 / 2-3 FEET  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 3 feet to 25 feet

Date started JULY 23 1993  
 Date completed JULY 23 1993

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 17 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name RICHARD LE BLANC Contractor  
 Address 4670 S. POLARIS AVENUE  
LAS VEGAS, NV 89103  
 Nevada contractor's license number issued by the State Contractor's Board 10-1817  
 Nevada driller's license number issued by the Division of Water Resources (the on-site driller) M-1817  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 10-18-93