WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42959
Permit No.
Basin 162

NOTICE OF INTENT NO. 12251

1. OWNER ~~JOHN AUSTIN~~ Edward Foley
MAILING ADDRESS
ADDRESS AT WELL LOCATION LOT 17 PAHRUMP NV

2. LOCATION SW ¼ SE ¼ Sec 32 T 19S N/S R 52 E NYE County
PERMIT NO. (Issued by Water Resources) 29-802-27 (Parcel No.) RANCHO DEL SOL (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	4	4
CALICHIE		4	6	2
CLAY		6	13	7
CALICHIE		13	19	6
CLAY		19	27	8
CALICHIE		27	29	2
CLAY		29	42	13
CALICHIE	WB	42	44	2
CLAY		44	51	7
CALICHIE	WB	51	55	4
CLAY		55	62	7
CALICHIE	WB	62	67	5
CLAY		67	73	6
CALICHIE	WB	73	75	2
CLAY		75	82	7
CALICHIE	WB	82	87	5
CLAY		87	102	15
CALICHIE	WB	102	105	3
CLAY		105	114	9
CALICHIE	WB	114	116	2
CLAY		116	128	12
CALICHIE	WB	128	132	4
CLAY		132	138	6
CALICHIE	WB	138	140	2
		140		140

Date started 9-21-93, 19
Date completed 9-23-93, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
OCT 13 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12.25 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
85\8	16.9	.188	0	140

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 1\8 X 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING CO. INC. (Contractor)
Address HCR 78 BOX 80358 PAHRUMP NV 89041 (Contractor)
Nevada contractor's license number 30880 issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on site or contractor)
Date 10-1-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627