



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER ED KEHOE ADDRESS AT WELL LOCATION LOT 150 MAPLE ST. PAHRUMP NV.  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SW 1/4 NE 1/4 Sec 24 T. 20S N/S R. 52 E. NYE County \_\_\_\_\_  
 PERMIT NO. 28-783-15 CHARLESTON PARK  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	3	3
CALICHE		3	7	4
CLAY		7	17	10
CALICHE		17	21	4
CLAY		21	32	11
CALICHE		32	35	3
CLAY		35	48	13
CALICHE	WB	48	52	4
CLAY		52	59	7
CALICHE	WB	59	61	2
CLAY		61	72	11
CALICHE	WB	72	76	4
CLAY		76	87	11
CALICHE	WB	87	94	7
CLAY		94	100	6
CALICHE	WB	100	102	2
CLAY		102	111	9
CALICHE	WB	111	116	5
CLAY		116	120	4
CALICHE	WB	120	123	3
CLAY		123	130	7
CALICHE	WB	130	139	9
CLAY		139	140	1
CALICHE	WB	140		140
CLAY				
CALICHE	WB			

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12.25 Inches 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
85\8	16.9	.188	0	140

Perforations:  
 Type perforation FACTORY SAW CUT  
 Size perforation 1-1/8 x 3  
 From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL  
 Static water level 4.7 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 9-7-93, 19\_\_\_\_\_  
 Date completed 9-10-93, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<b>RECEIVED</b>			

Div. of Water Resources  
 Branch Office - Las Vegas, NV

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GREAT BASIN DRILLING CO., INC. Contractor  
 Address HCR 78 BOX 80358 PAHRUMP NV 89041 Contractor  
 Nevada contractor's license number 30880 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
 Signed Thomas Dan By driller performing actual drilling on site or contractor  
 Date 9-16-93