



Log No. 42970
 Permit No. _____
 Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 11707

1. OWNER KYLER ESCALERA ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____ LOT 244 MARTIN AVE
 _____ PAHRUMP NV
 2. LOCATION SW 1/4 SW 1/4 Sec 26 T. 20S N/S R. 52 E. NYE County _____
 PERMIT NO. 28-612-01 VEGAS ACRES 2 Subdivision Name _____
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	6	6
CALICHE		6	13	7
CLAY		13	18	5
CALICHE		18	22	4
CLAY		22	36	14
CALICHE	WB	36	38	2
CLAY		38	56	18
GRAVEL	WB	56	120	64
		120		120

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12.25 Inches 0 Feet 120 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
85\8	16.9	.188	0	120

Perforations:
 Type perforation FACTORY SAW CUT
 Size perforation 1\8 x 3\16
 From 100 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

RECEIVED
 OCT 22 1993
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 4-6-93, 19_____
 Date completed 4-8-93, 19_____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 48 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO., INC. Contractor
 Address HCR 78 BOX 80358 Contractor
PAHRUMP NV 89041
 Nevada contractor's license number 30880 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas D... By driller performing actual drilling on site or contractor
 Date 10-13-93