

Log No. 42975

Permit No. \_\_\_\_\_

Basin. 162



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12241

1. OWNER EUD CORBIN ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_ LOT 275 PILTZ ST  
 \_\_\_\_\_ PAHRUMP NV  
 2. LOCATION NW 1/4 NW 1/4 Sec. 9 T. 20S N/S R. 53 E. NYE County  
 PERMIT NO. 35-162-13 CAL VEGAS RANCHOS  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE  
 New Well  Replace  Recondition  Domestic  Irrigation  Test  Cable  Rotary  RVC  
 Deepen  Abandon  Other \_\_\_\_\_  Municipal/Industrial  Monitor  Stock  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	5	5
CALICHIE		5	9	4
CLAY		9	16	7
CALICHIE		16	19	3
CLAY		19	27	8
CALICHIE		27	29	2
CLAY		29	37	8
CALICHIE	WB	37	41	4
CLAY		41	56	15
CALICHIE	WB	56	60	4
CLAY		60	69	9
CALICHIE	WB	69	74	5
CLAY		74	88	14
CALICHIE	WB	88	91	3
CLAY		91	102	11
CALICHIE	WB	102	107	5
CLAY		107	113	6
CALICHIE	WB	113	117	4
CLAY		117	125	8
CALICHIE	WB	125	133	8
CLAY		133	137	4
CALICHIE	WB	137	140	3
		140		140

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
12.25 Inches 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
85\B	16.9	.188	0	140

Perforations:  
 Type perforation FACTORY SAW CUT  
 Size perforation 1\B X 3"  
 From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL  
 Static water level 48 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GREAT BASIN DRILLING CO. INC.  
 Contractor  
 Address HCR 78 BOX 80358  
PAHRUMP NV 89041  
 Contractor  
 Nevada contractor's license number 30880  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1642  
 Division of Water Resources, the on-site driller  
 Signed Thomas Dun  
 By driller performing actual drilling on site or contractor  
 Date 10-1-93

Date started 9-7-93 19\_\_\_\_\_  
 Date completed 9-8-93 19\_\_\_\_\_

7. WELL TEST DATA  
 TEST METHOD:  Bailer  Pump  Air Lift  

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

 Div. of Water Resources  
 Branch Office Las Vegas, NV

RECEIVED  
 OCT 13 1993

