WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42976
Permit No.
Basin 162

NOTICE OF INTENT NO 12242

1. OWNER BUD CORBIN
MAILING ADDRESS
ADDRESS AT WELL LOCATION LOT 309 IRENE ST
PAHRUMP NV

2. LOCATION NW ¼NW ¼ Sec 9 T 20S N/S R 53 E NYE County
PERMIT NO. (Issued by Water Resources) 35-161-13 (Parcel No.) CAL VEGAS RANCHOS (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	3	3
CALICHIE		3	6	3
CLAY		6	14	8
CALICHIE		14	17	3
CLAY		17	25	8
CALICHIE		25	27	2
CLAY		27	35	8
CALICHIE	WB	35	38	3
CLAY		38	46	8
CALICHIE	WB	46	49	3
CLAY		49	54	5
CALICHIE	WB	54	57	3
CLAY		57	61	4
CALICHIE	WB	61	64	3
CLAY		64	70	6
CALICHIE	WB	70	75	5
CLAY		75	89	14
CALICHIE	WB	89	92	3
CLAY		92	100	8
CALICHIE	WB	100	103	3
CLAY		103	111	8
CALICHIE	WB	111	113	2
CLAY		113	127	14
CALICHIE	WB	127	129	2
CLAY		129	139	10
CALICHIE	WB	139	140	1
		140		140

Date started 9-7-93, 19
Date completed 9-8-93, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
OCT 13 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12.25 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.9	.188	0	140

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 1/8 X 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING CO. INC. (Contractor)
Address HCR 78 BOX 80358 (Contractor)
PAHRUMP NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dam (By driller performing actual drilling on site or contractor)
Date 10-1-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627