

OFFICE USE ONLY
 Log No. 42981
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12248

1. OWNER FULLEN ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____ LOT 6 PAGE ST
 _____ PAHRUMP NV
 2. LOCATION NE 1/4 NW 1/4 Sec 20 T.20S N/S R. 53 E NYE County _____
 PERMIT NO. 39-084-06 UNIT 8B CALVADA VALLEY
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	3	3
CALICHIE		3	6	3
CLAY		6	19	13
CALICHIE		19	34	15
CLAY		34	53	19
CALICHIE	WB	53	54	1
CLAY		54	71	17
CALICHIE	WB	71	75	4
CLAY		75	83	8
CALICHIE	WB	83	88	5
CLAY		88	101	13
CALICHIE	WB	101	103	2
CLAY		103	117	14
CALICHIE	WB	117	120	3
CLAY		120	128	8
CALICHIE	WB	128	130	2
CLAY		130	138	8
CALICHIE	WB	138	140	2
		140		140

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 140 Feet
 12.25 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
85\8	16.9	.188	0	140

Perforations:
 Type perforation FACTORY SAW CUT
 Size perforation 1.8 X 3"
 From 100 feet to 120 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 _____
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 52 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started _____, 19____
 Date completed 9-22-93, 19____
9-25-93

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
RECEIVED		
NOV 12 1993		
Div. of Water Resources Branch Office - Las Vegas, NV		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. INC.
 Contractor
 Address HCR 7B BOX 80358
PAHRUMP NV 89041
 Contractor
 Nevada contractor's license number 30880
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1642
 Division of Water Resources, the on-site driller.
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 10-23-93