WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45984
Permit No.
Basin

NOTICE OF INTENT NO. 12233

1. OWNER MAX HENDRICKSON
MAILING ADDRESS
ADDRESS AT WELL LOCATION LOT 10 AMARILLO ST
PAHRUMP NV

2. LOCATION NE ¼ SW ¼ Sec. 29 T. 20S N/S R. 53 E. NYE County
PERMIT NO. (Issued by Water Resources) 40-253-10 (Parcel No.) UNIT 5 CALVADA (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	5	5
CALICHIE		5	7	2
CLAY		7	19	12
CALICHIE		19	22	3
CLAY		22	37	15
CALICHIE		37	40	3
CLAY		40	44	4
CALICHIE		44	47	3
CLAY		47	57	10
CALICHIE	WB	57	61	4
CLAY		61	77	16
CALICHIE	WB	77	80	3
CLAY		80	92	12
CALICHIE	WB	92	95	3
CLAY		95	106	11
CALICHIE	WB	106	112	6
CLAY		112	117	5
CALICHIE	WB	117	119	2
CLAY		119	125	6
CALICHIE	WB	125	127	2
CLAY		127	136	9
CALICHIE	WB	136	139	3
CLAY		139	140	1
		140		140

Date started 9-6-93, 19
Date completed 9-8-93, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
OCT 13 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12.25 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
85\8	16.9	.188	0	140

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 1\8 X 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 52 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING CO. INC. (Contractor)
Address HCR 78 BOX 80358 (Contractor)
PAHRUMP NV 89041

Nevada contractor's license number 30880 issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed (By driller performing actual drilling on site or contractor)
Date 9-23-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627