



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 10355

1. OWNER KINGS LAND DEVELOPMENT ADDRESS AT WELL LOCATION LOT 152 BETTY ST PAHRUMP NV
 MAILING ADDRESS _____
 2. LOCATION NW 1/4 SW 1/4 Sec 9 T.21S N/S R.53 E. NYE County _____
 PERMIT NO. 35-173-08 CAL VEGAS Subdivision Name _____
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY			14	14
CALICHIE		14	16	2
CLAY		16	35	19
CALICHIE		35	37	2
CLAY		37	48	11
CALICHIE	WB	48	50	2
CLAY		50	61	11
CALICHIE	WB	61	63	2
CLAY		63	80	17
CALICHIE	WB	80	82	2
CLAY		82	97	15
CALICHIE	WB	97	99	2
CLAY		99	112	13
CALICHIE	WB	112	114	2
CLAY		114	128	14
CALICHIE	WB	128	130	2
CLAY		130	140	10
		140		140

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From 12.25 Inches 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
85\8	16.9	.188	0	140

Perforations:
 Type perforation FACTORY SAW CUT
 Size perforation 1\8 X 3"
 From 100 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 _____
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 48 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

RECEIVED
 OCT 22 1993
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 1-8-93, 19____
 Date completed 1-9-93, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. INC. Contractor
 Address HCR 78 BOX 80358 PAHRUMP NV 89041 Contractor
 Nevada contractor's license number 30880 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas D...
 By driller performing actual drilling on site or contractor
 Date 10-13-93

