



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 12225

1. OWNER ARLEE BOOHER ADDRESS AT WELL LOCATION QUARTER HORSE  
 MAILING ADDRESS PAHRUMP NV

2. LOCATION SW 1/4 NW 1/4 Sec 17 T21S N/S R 54 E NYE County NYE  
 PERMIT NO. 45-181-08

Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	5	5
CALICHE		5	7	2
CLAY		7	17	10
CALICHE		17	21	4
CLAY		21	43	22
CALICHE		43	45	2
CLAY		45	49	4
CALICHE	WB	49	52	3
CLAY		52	68	16
CALICHE	WB	68	71	3
CLAY		71	78	7
CALICHE	WB	78	80	2
CLAY		80	96	16
CALICHE	WB	96	98	2
CLAY		98	117	19
CALICHE	WB	117	120	3
CLAY		120	129	9
CALICHE	WB	129	134	5
CLAY		134	140	6
		140		140

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
 From 12.25 Inches To 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
85\8	16.9	.188	0	140

Perforations:  
 Type perforation FACTORY SAW CUT  
 Size perforation 1\8 X 3"  
 From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
50 Depth of Seal \_\_\_\_\_  
 Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

Date started 8-20-93, 19\_\_\_\_  
 Date completed 8-21-93, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<b>RECEIVED</b>		
<b>OCT 13 1993</b>		
Div. of Water Resources		
Branch Office - Las Vegas, NV		

9. WATER LEVEL  
 Static water level 55 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
GREAT BASIN DRILLING CO., INC.  
 Name \_\_\_\_\_ Contractor  
 Address HCR 78 BOX 80358 Contractor  
PAHRUMP NV 89041  
 Nevada contractor's license number 30880 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1642 Division of Water Resources, the on-site driller.  
 Signed Thomas Dean  
 By driller performing actual drilling on site or contractor  
 Date 9-23-93

