

OFFICE USE ONLY
 Log No. 42997
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 11614

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Robert Clark ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____
 2. LOCATION NW 1/4 NW 1/4 Sec. 19 T. 215 N/S R. 54 E Nye County _____
 PERMIT NO. 45-262-17 Parcel No. _____ Subdivision Name Green Saddle Ranch

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	8	8
Caliche		8	10	2
Clay		10	19	9
Caliche		19	23	3
Clay		22	38	16
Caliche		38	41	3
Clay		41	49	8
Caliche	wB	49	56	7
Clay		56	64	8
Caliche	wB	64	67	3
Clay		67	85	18
Caliche	wB	85	88	3
Clay		88	100	12
Caliche	wB	100	102	2
Clay		102	116	14
Caliche	wB	116	118	2
Clay		118	130	12
Caliche	wB	130	136	6
Clay		136	140	4

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 3/8</u>	<u>16.90</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation Factory Saw Cut
 Size perforation 1 1/2
 From 120 feet to 140 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

RECEIVED
 OCT 22 1993
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 3-8, 1993
 Date completed 3-8, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 49 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HER 78 Box 80358 Contractor
Pahrump NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas Dan
 By driller performing actual drilling on site or contractor
 Date 3-8-93