


WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340



Permit No. 43010  
Bath

ADDRESS AT WELL LOCATION NORTH LAS VEGAS TRAIL FARM/ 530 N LAS VEGAS BLVD

1. OWNER Rebel 1/2 BEAUBERT & Assoc

MAILING ADDRESS 833 NEWADA Hwy STE 4

BOULDER BLVD 89005

2. LOCATION MD 1/4 SW 1/4 Sec 34 T 19 R 62 E Clark Co. County

PERMIT NO. MD-8334 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Municipal/Industrial  
 Irrigation  Test  Stock  
 Monitor  Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>POREY GRADED SAND</u>		<u>0</u>	<u>8</u>	<u>8</u>
<u>CALICHE</u>		<u>8</u>	<u>9</u>	<u>1</u>
<u>SILTY SAND</u>		<u>9</u>	<u>12</u>	<u>3</u>
<u>HALICHE</u>		<u>12</u>	<u>13</u>	<u>1</u>
<u>SILTY SAND</u>		<u>13</u>	<u>29</u>	<u>16</u>
<u>PARTIANT GRAVEL</u>		<u>29</u>	<u>31</u>	<u>2</u>
<u>SANDY SILT</u>		<u>31</u>	<u>45</u>	<u>14</u>
<u>SANDY GRAVEL</u>		<u>45</u>	<u>48</u>	<u>3</u>
<u>SILTY SAND</u>		<u>48</u>	<u>52</u>	<u>4</u>
<u>SILTY CLAY</u>		<u>52</u>	<u>120</u>	<u>68</u>

8. WELL CONSTRUCTION  
 Depth Drilled 120 Feet Depth Cased 120 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8 Inches To 120 Feet  
 Inches. 0 Feet. 120 Feet  
 Inches.      Feet.      Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>	<u>0.64</u>	<u>0.154</u>	<u>0</u>	<u>120</u>

Perforations:  
 Type perforation FRAGILE SUDT  
 Size perforation 0.0201  
 From 80 feet to 120 feet  
 From      feet to      feet  
 From      feet to      feet  
 From      feet to      feet  
 From      feet to      feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  Cement Grout  
 Concrete Grout

Gravel Packed:  Yes  No  
 From 75 feet to 120 feet

9. WATER LEVEL  
 Static water level:      feet below land surface  
 Artesian flow:      G.P.M. P.S.I.  
 Water temperature:      °F Quality:     

7. WELL TEST DATA  
 TEST METHOD:  Bailor  Pump  Air Lift  
 G.P.M. (Feet Below Static) Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name: RICHARD LE BLANC/CONVERSE (hus)  
 Address: 4670 So. BEARIS AVE  
LAS VEGAS NV 89103  
 Nevada contractor's license number 11817  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller: 11817  
 Signed: [Signature] by drilling/performing actual drilling on site or contractor  
 Date: 10/18/93