WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43028
Permit No.
Basin 212

NOTICE OF INTENT NO. 12-07

1. OWNER ARCO C/O BROADBENT & ASSOCIATES
MAILING ADDRESS 833 NEVADA HWY STE 4
BOULDER CITY NV 89005

ADDRESS AT WELL LOCATION 2728 LAS VEGAS BLVD SOUTH
ARCO 5310

2. LOCATION NE ¼ SE ¼ Sec. 9 T. 21 N/S R. 61 E CLARK County

PERMIT NO. MD-2308 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| ASPHALT / FILL | | 0 | 2.5 | 2.5 |
| SILTY SAND | | 2.5 | 5.5 | 3 |
| CEMENTED GRAVEL | | 5.5 | 7 | 1.5 |
| SANDY SILT | | 7 | 14 | 7 |
| CALICHE | | 14 | 14.5 | 0.5 |
| SILTY CLAY | | 14.5 | 20 | 5.5 |

RECEIVED
OCT 21 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started SEPT 10, 19 93
Date completed SEPT 10, 19 93

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 8 Inches | | 0 Feet | 20 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2.375 | 0.64 | 0.154 | 0 | 20 |
| | | SCH 40 | | |

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 5 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-1½ / 1½-2½ BENT
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 2½ feet to 20 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RICHARD LE BLANC / CONVERSE CONSULT (Contractor)
Address 4670 SO. POLARIS AVE (Contractor)
LAS VEGAS NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources the on-site driller M1817
Signed (By driller performing actual drilling on site or contractor)
Date 10/18/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627