WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43037
Permit No.
Basin 212

NOTICE OF INTENT NO. 10176

1. OWNER CAL NEV PIPELINE CO
MAILING ADDRESS 412 HOSPITALITY LANE STE 202 PO BOX 6346 SAN BERNARDINO CA 92412

ADDRESS AT WELL LOCATION ALONG VALLEY VIEW, SOUTH OF VALLEY VIEW & HACIENDA INTERSECTION

2. LOCATION SE ¼ NE ¼ Sec. 30 T 21 N/S R 61 E CLARK County

PERMIT NO. MD-2280 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT/FILL		0	1	1
GRAVELLY SAND		1	5	4
SILTY CLAY		5	8.5	3.5
CALICHE		8.5	9	0.5
SILTY CLAY		9	14	5
CLAYEY SILT		14	15	1
CLAY		15	18	3
SILTY SAND		18	20	2
CLAY		20	21	1
CLAYEY FINE SAND		21	23	2
SANDY CLAY		23	24	1
CLAYEY TO GRAVELLY SAND		24	28	4
CLAY		28	31	3
SANDY GRAVEL		31	33	2
SILTY CLAY		33	35	2
CALICHE		35	37	2
CLAY		37	43	6
CLAYEY SAND		43	45	2
GRAVELLY CLAY		45	48	3
SANDY GRAVEL		48	55	7
GRAVELLY TO SANDY CLAY		55	60	5
CALICHE		60	64	4
SANDY CLAY		64	66	2
GRAVELLY SAND		66	69.5	3.5
GRAVELLY CLAY		69.5	72	2.5

Date started 5/4/93, 1993
Date completed 5/4, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
OCT 21 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 72 Feet Depth Cased 72 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	72 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	1.9	(SCH40) 0.237	0	72

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 42 feet to 72 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-33, 33-35 BENT
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 35 feet to 72 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RICHARD LEBLANC/CONVERSE CONS. (Contractor)
Address 4670 SO. POLARIS AVE (Contractor)
LAS VEGAS NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1817
Signed (By driller performing actual drilling on site or contractor)
Date 10-18-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627