WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43040
Permit No.
Basin 212

NOTICE OF INTENT NO. 10175

1. OWNER CAL NEV PIPELINE CO.
MAILING ADDRESS 412 HOSPITALITY LANE STE 202 PO BOX 6346 SAN BERNARDINO CA 92412

ADDRESS AT WELL LOCATION ALONG HACIENDA AVE WEST OF VALLEY VIEW & HACIENDA INTERSECTION

2. LOCATION SE ¼ NE ¼ Sec. 30 T 21 N/S R 61 E CLARK County

PERMIT NO. MO-2280 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT/FILL		0	1	1
CLAYEY SANDY SILT		1	4	3
CLAYEY SAND		4	5	1
SILTY CLAY		5	8	3
CLAYEY SAND		8	9	1
SILTY CLAY		9	13	4
CALICHE		13	15	2
SILTY CLAY		15	17	2
SILTY SAND		17	20	3
SANDY SILT		20	22	2
SILTY SAND		22	32	10
CLAYEY GRAVEL		32	33	1
GRAVELLY SAND		33	41	8
CALICHE		41	43	2
SANDY GRAVEL		43	44	1
CLAYEY SAND		44	46	2
SILTY CLAY		46	48	2
CALICHE		48	50	2
PEBBLE CALICHE		50	56	6
CLAYEY SAND		56	58	2
GRAVELLY CLAY		58	62	4
CALICHE		62	65	3
GRAVELLY SILT		65	70	5
SANDY CLAY		70	72	2
SILTY SAND		72	75	3

Date started MAY 4, 19 93
Date completed MAY 4, 19 93

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
OCT 27 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 75 Feet Depth Cased 70 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	75 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	70

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 40 feet to 70 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-34', 34-36' BENT.
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 36 feet to 75 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DON WILSON / CONVERSE CONSULT. (Contractor)
Address 4670 SO. POLARIS AVE (Contractor)
LAS VEGAS NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589
Signed (By driller performing actual drilling on site or contractor)
Date 10-26-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627