



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24094

1. OWNER Washoe County Utility Division ADDRESS AT WELL LOCATION Spanish Springs Site #7  
 MAILING ADDRESS P.O. Box 11130  
Reno, NV 89520

2. LOCATION NE 1/4 SW 1/4 Sec. 13 T. 21 N. S. R. 20 E. Washoe County  
 PERMIT NO. NA Issued by Water Resources Parcel No. NA Subdivision Name NA

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fine sand & silt		0	5	5
Coarse granite sand		5	52	47
Granitic sand/clay		52	64	12
Brown silty clay/sand		64	72	8
Brn/red silty clay		72	85	13
Tan silty clay/sand		85	95	10
White sand/clay		95	105	10
Decomposed granodiorite		105	190	85
Granodiorite/white clay		190	250	60
Lost circulation		250	270	20
Granodiorite		270	330	60
Granodiorite/white clay		330	360	30

'93 DEC -9 AND '90

STATE ENGINEER

8. WELL CONSTRUCTION  
 Depth Drilled 360 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)  
 From 0 Feet To 360 Feet  
7 7/8 Inches  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		Galvanized	+2	169

Perforations:  
 Type perforation Slotted pipe  
 Size perforation 1/8 X 2 1/2  
 From 169 feet to 360 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 60  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 60 feet to 360 feet

9. WATER LEVEL  
 Static water level 214.02' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Humboldt Drilling & Pump Co., Inc.  
 Contractor

Date started August 29, 1993  
 Date completed September 1, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>did</u>	<u>←</u>	<u>did not test</u>	
		<u>Air on Rig</u>	

Address P.O. Box 590 Contractor  
Winnemucca, NV 89446

Nevada contractor's license number issued by the State Contractor's Board 015234  
 Nevada driller's license number issued by the Division of Water Resources, then-site driller I-1195-1

Signed C. P. Cople  
 By driller performing actual drilling on site or contractor  
 Date 11-1-93