

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23311

1. OWNER MARK LERENZO ADDRESS AT WELL LOCATION HRC 30 Box 30
 MAILING ADDRESS HRC 30 Box 30 30 Box B lot 1 ELKO
ELKO NV 89803

2. LOCATION SW 1/4 SW 1/4 Sec. 35 T. 34 N/S R. 56 E ELKO County _____
 PERMIT NO. 06-318-03-07 SAGE LAKE Subdivision Name _____
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	6	6
SANDSTONE		6	63	57
CLAY		63	110	47
Loose Gravel	X	110	120	10
CLAY		120	125	5
SANDSTONE		125	139	14
Loose Rock	X	139	143	4
CLAY		143	179	36
HARD ROCK		179	185	6
Boulders	X	185	190	5
Hard Rock		190	192	2
Gravel	X	192	207	15
Hard Rock		207	215	8
SOFT SANDSTONE		215	217	2
Gravel	X	217	225	8
CLAY		225	227	2
Hard Rock		227	245	18

93 DIG - 8 AUG 93 STATE ENGINEER

8. WELL CONSTRUCTION
 Depth Drilled 245 Feet Depth Cased 245 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 3/4 Inches To 0 Feet 245 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8"</u>		<u>188</u>	<u>±2</u>	<u>245</u>

Perforations:
 Type perforation Slots
 Size perforation 3 x 3/16

From 60 feet to 90 feet
 From 100 feet to 120 feet
 From 140 feet to 160 feet
 From 180 feet to 245 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 60

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From 60 feet to 245 feet

9. WATER LEVEL
 Static water level 50 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

Date started 10-30 1993
 Date completed 11-5 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>250-300</u>		<u>5</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Fertig Drilling Co Contractor
 Address PO Box 525 ELKO NV Contractor
89803

Nevada contractor's license number issued by the State Contractor's Board 31904
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed Shaulc T. ...
 By driller performing actual drilling on site or contractor
 Date 12-2-93