

WHITE-DIVISION OF WATER RESOURCES
 CANARY-CLIENT'S COPY
 PINK-WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 43094943095
 Permit No. _____
 Basin. 4-6d

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24297

1. OWNER BARRICK GOLDSTRIKE ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. BOX 29 BARRICK GOLDSTRIKE MINE _____
ELKO, NV 89801
 2. LOCATION NE 1/4 SE 1/4 Sec. 19 T. 36 N/S R. 50 E EUREKA County _____
 PERMIT NO. M/O-441A Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	20	20
CLAY & GRAVEL		20	40	20
BOULDERS		40	50	10
GRAVEL & CLAY		50	100	50
SAND & GRAVEL		100	210	110
FRACTURED BLACK ROCK & BROWN CLAY		210	295	85
GRAY CLAY & GRAVEL		295	320	25
GRAVEL & SAND		320	340	20
GRAVEL & BROWN CLAY		340	360	20
GRAVELS		360	480	120
FRACTURED WHITE ROCK		480	510	30
SMALL GRAVEL & SAND		510	585	75
FRACTURED & BROWN ROCK		585	650	65
FRACTURED GRAY ROCK		650	680	30
HARD FRACTURED GRAY & BLACK ROCK		680	715	35
HARD BLACK ROCK		715	800	85

8. WELL CONSTRUCTION
 Depth Drilled 800 Feet Depth Cased 700 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
14 Inches 0 Feet 40 Feet
6 1/2 Inches 40 Feet 800 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7	28	.375	+3	40
#1: 1 1/2	2	SCH 40	+3	700 <u>43094</u>
#2: 1 1/2	2	SCH 40	3	415 <u>43095</u>

Perforations:
 Type perforation SLOTTED
 Size perforation 1/8"
 From #1: 700 feet to 740 feet
 From #2: 415 feet to 455 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From #1: 690-740 feet to #2: 405-465 feet

9. WATER LEVEL
 Static water level 125 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 70 °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING Contractor
 Address 2286 WEST 1500 SOUTH Contractor
SALT LAKE CITY, UTAH 84104
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1829
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date DECEMBER 13, 1993

Date started NOVEMBER 26, 1993
 Date completed NOVEMBER 30, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			

'93 DEC 17 P 2 33
 RECEIVED
 STATE ENGINEERS OFFICE