WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43110
Permit No.
Basin 4-70

NOTICE OF INTENT NO. 25386

1. OWNER Royce L. Hackworth
MAILING ADDRESS 1031 Dotta Drive
Elko, NV 89801

ADDRESS AT WELL LOCATION North side of East Hunt between Dearth & Barren Road

2. LOCATION SW ¼ SE ¼ Sec. 1 T 36 N/S R 38 E Humboldt County

PERMIT NO. (Issued by Water Resources) | 10-423-18 (Parcel No.) | Sage Hills Estates #2 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Blow Sand		0	2	2
Brown Clay & Boulders		2	22	20
Brown Siltstone & small gravel		22	85	63
Sand & gravel	X	85	125	40
Siltstone & peagravel	X	125	140	15

'93 DEC 27 P12:27
STATE ENGINEER

Date started 12-3-, 1993
Date completed 12-3, 1993

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
60		4

8. WELL CONSTRUCTION

Depth Drilled 140 Feet Depth Cased 134 Feet

HOLE DIAMETER (BIT SIZE)

10 5/8 Inches From 0 Feet To 140 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1½	134

Perforations:
Type perforation Millslot
Size perforation 3/16 X 3
From 114 feet to 134 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [X] Poured

Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 134 feet

9. WATER LEVEL

Static water level 55 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hackworth Drilling, Inc. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020582

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689

Signed Dave Hersh
By driller performing actual drilling on site or contractor

Date 12-23-1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627