

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 43119 43115  
 Permit No. 71  
 Basin 71

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20728

1. OWNER Evelyn Johnson ADDRESS AT WELL LOCATION 7650 Germain Dr.  
 MAILING ADDRESS P.O. Box 1477 Winnemucca, NV 89446  
 2. LOCATION NE 1/4 SE 1/4 Sec. 13 T. 35 N/S R. 37 E Humboldt County  
 PERMIT NO. "NA" 13-581-08 NONE  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Boulders w/s Clay		0	40	
Cemented Rock		40	120	
Cemented Rock w/s Clay		120	180	
Cemented Rock with stringers of gravel		180	200	
<i>Deposited with NO2 67867</i>				
<i>N 90:905786</i>				
<i>W 117:755817 MA997</i>				
<i>93 DEC 21 10:46</i>				
<i>STATE ENGINEERS OFFICE</i>				

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10" Inches 0 Feet 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		.188	0	200

 Perforations:  
 Type perforation FACTORY  
 Size perforation 1/8 X 2 1/2  
 From 180 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 ft.  Neat Cement  
 Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 200 feet

Date started October 23, 1993  
 Date completed November 1, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15</u>		<u>6 Hrs.</u>

9. WATER LEVEL  
 Static water level 142 feet below land surface  
 Artesian flow None G.P.M. None P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Dave McNinch Contractor  
 Address P.O. Box 585 Contractor  
Winnemucca, NV 89446  
 Nevada contractor's license number issued by the State Contractor's Board 5437  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 730  
 Signed Aerale Lu Montz  
 By driller performing actual drilling on site or contractor  
 Date 12-16-93