

LOG USE ONLY
 Log No. **43118**
 Permit No. **1**
 Basin. **6-27**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **18104**

1. OWNER Wetlands Enhancement Pro. ADDRESS AT WELL LOCATION Pembroke Lane +
E. Truckee Meadows Kimlick Lane
Reno, Nv. Reno, Nv.
 2. LOCATION NE 1/4 NE 1/4 Sec. 22 T. 19 N/S R. 20 E. Washoe County
 PERMIT NO. M/10685 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other auger

6. LITHOLOGIC LOG MW-1

Material	Water Strata	From	To	Thick-ness
<u>brown silty sand</u>		<u>0</u>	<u>11'</u>	<u>11'</u>
<u>gray fine sand</u>	<u>Yes</u>	<u>11'</u>	<u>13'</u>	<u>2'</u>
<u>dark gray clayey silt</u>		<u>13'</u>	<u>19'</u>	<u>6'</u>
<u>gray silty fine sand</u>		<u>19'</u>	<u>22'</u>	<u>3'</u>

8. WELL CONSTRUCTION
 Depth Drilled 22 Feet Depth Cased 22 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 22
8 Inches 0 Feet 22 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>		<u>PYLSch. 40</u>	<u>0</u>	<u>21.5</u>

Perforations:
 Type perforation factory slot
 Size perforation .020
 From 0 feet to 21.5 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 5'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 5 feet to 22 feet

9. WATER LEVEL
 Static water level 10 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature 60 °F Quality N/A

Date started 6/21, 19 93
 Date completed 6/21, 19 93

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

N/A

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Andresen Drilling Contractor
 Address 1635 Belford Rd. Contractor
Reno, Nv.
 Nevada contractor's license number issued by the State Contractor's Board 34525
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 6/26/93