

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 4321
 Permit No. _____
 Basin 6-84
 NOTICE OF INTENT NO. 21732

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Rose Williams ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 2500 Twin Springs Rd 5455 ~~2500~~ Twin Springs Rd
Reno, Nv 89510
 2. LOCATION NE 1/4 SE 1/4 Sec. 25 T. 22 N/S R. 21 E Washoe County
 PERMIT NO. 077-160-11 - Palomino Valley Dist 1 25-2-1-10
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gray clay & sands		298	312	14
Scattered rock & clay and sand		312	359	47
Hard rock		359	361	2
Multicolored rock and sand		361	434	73
T.D. 434 ft				

93 DEU 29 AND 34
STATE ENGINEER
Q&A by log # 69560
see also log # 68509

8. WELL CONSTRUCTION
 Depth Drilled 434 Feet Depth Cased 434 Feet
 HOLE DIAMETER (BIT SIZE)
 From 298 To 434
6 Inches Feet Feet
 _____ Inches Feet Feet
 _____ Inches Feet Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	9.66	.188	174	434

 Perforations:
 Type perforation factory
 Size perforation 3/32" X 3
 From 374 feet to 414 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal refer to original log Neat Cement
 Cement Grout
 Placement Method: Pumped Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started 9/29/92, 19_____
 Date completed 9/29/92, 19_____
 7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
seepage		

9. WATER LEVEL
 Static water level 180 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
 Contractor
 Address 625 Spice Islands Dr Suite L
 Contractor
Sparks, Nv 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1132
 Division of Water Resources, the on-site driller
 Signed _____
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 10/1/92