WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43122
Permit No.
Basin 6-84

NOTICE OF INTENT NO. 23373

1. OWNER PHILLIP JEROME
MAILING ADDRESS 5900 Grass Valley Road
Reno, NV 89510

ADDRESS AT WELL LOCATION Same

2. LOCATION NE ¼ SW ¼ Sec. 33 T. 22N N/S R. 21 E. Washoe County
N23
PERMIT NO. (Issued by Water Resources) 077-350-04 (Parcel No.) Palomino Valley (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
See log # 18575 for orig. comp.				
Static Water level in well at 187 ft. (½ GPM)				
Fill		217	224	7
Reddish brown volcanic rock		224	258	34
Soft zone (NO WATER)		258	260	2
Reddish brown volcanic rock		260	358	98
Soft zone	X	358	360	2
Reddish brown volcanic rock		360	367	7
Green volcanic rock		367	387	20
Gray volcanic rock		387	407	20
Soft zone	X	407	409	2
Gray volcanic rock		409	421	12

'93 DEC 13 P2:22
STATE ENGINEER

Date started 11-29-93, 19
Date completed 12-01-93, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 421 Feet Depth Cased 421 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 1/8 Inches	217 Feet	421 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5" OD		.188	0	421

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 356 feet to 376 feet
From 396 feet to 416 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal N/A
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 224 feet to 421 feet

9. WATER LEVEL
Static water level 187 feet below land surface
Artesian flow 12 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed Gary D. Hedman (By driller performing actual drilling on site or contractor)
Date December 1, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627