

OFFICE USE ONLY  
 Log No. 43129  
 Permit No. \_\_\_\_\_  
 Basin 6-85

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT No. 20709

1. OWNER MAX BOWEN ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 725 Moran Street, Apt. #14 Campo Rico Lane  
Reno, NV 89502 Reno, NV 89510  
 2. LOCATION NE 1/4 NE 1/4 Sec. 14 T. 21N N/S R 20 E Washoe County  
 PERMIT NO. 076-360-68 Spanish Springs  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay with decomposed granite		1	9	8
Brown fine sand		9	18	9
Brown clay w/DG		18	61	43
Soft zone, brown sand		61	63	2
Brown sandy clay		63	116	53
Granite sands		116	119	3
Brown sandy clay		119	142	23
Granite sands		142	151	9
Brown sandy clay		151	179	28
Soft zone	X	179	188	9
Brown clay		188	205	17
Soft zone, (granite sands) X		205	242	37
Soft brown sandy clay		242	250	8

8. WELL CONSTRUCTION  
 Depth Drilled 250 Feet Depth Cascd. 250 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 50 Feet  
8 5/8 Inches 50 Feet 250 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	250

Perforations: factory sawed slot  
 Type perforation \_\_\_\_\_  
 Size perforation 3/32 x 3 x 5 around  
 From 185 feet to 245 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 250 feet

9. WATER LEVEL  
 Static water level 114 feet below land surface  
 Artesian flow 22 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality clear

Date started 12-2-93, 19\_\_\_\_\_  
 Date completed 12-6-93, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling, Inc. Contractor  
 Address P.O. Box 12370 Contractor  
Reno, NV 89510  
 Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada driller's license number issued by the 923  
 Division of Water Resources, the on-site driller.  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date December 9, 1993