

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 43133
 Permit No. _____
 Basin 6-87

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19000

1. OWNER Scott Camp ADDRESS AT WELL LOCATION 5837
 MAILING ADDRESS 5837 Stephens Rd Stephens Rd
 2. LOCATION NE 1/4 SE 1/4 Sec 26 T. 18 N. S. R. 19 E. Washoe County
 PERMIT NO. 49-051-64 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand + Gravel, large		0	23	23
Clay, tan		23	31	8
Gravel, large		31	73	42
Rock, dark grey		73	109	36
Clay, tan		109	126	17
Gravel, large-consisting of - Granit, Quartz, Red, tan, Green, w/clay seams	X	126	295	169

93 DEC -2 11:01 AM STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 295 Feet Depth Cased 295 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
1 1/4 Inches 0 Feet 5.0 Feet
9/8 Inches 5.0 Feet 295 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.97	1.88	0	295

 Perforations:
 Type perforation factory mill slot
 Size perforation 1/8
 From 1.95 feet to 2.15 feet
 From 2.35 feet to 2.55 feet
 From 2.75 feet to 2.97 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 5ft Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 5ft feet to 295 feet

9. WATER LEVEL
 Static water level 204 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 56 °F Quality _____

Date started 10/26/1993
 Date completed 11/7/1993

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
30	<u> </u>	<u>2</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Melkay Drilling Contractor
 Address 2290 Pioneer Drive Contractor
Reno, Nevada 89509
 Nevada contractor's license number 14170
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1261
 Division of Water Resources, the on-site driller
 Signed Stone Melkay
 By driller performing actual drilling on site Contractor
 Date 11/18/93