

FOR USE ONLY

Log No. 4156
 Permit No. 6-187
 Basis

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23868

1. OWNER Granite Construction Co ADDRESS AT WELL LOCATION Robb Drive - Interstate I-80
 MAILING ADDRESS P. O. Box 2087 Interchange
Sparks, Nv 89432

2. LOCATION SW 1/4 NE 1/4 Sec 18 T 19 N/S R 19 E Washoe County
 PERMIT NO. 39-112-10 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE Exploration
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
The SWL was checked and the Total Depth was checked				
	SWL:	262.5	feet	
	T.D.:	570	feet	
This well was filled with plug mud - coarse from 570 ft to 67 ft				
The first three bags were poured at a very slow rate and the fill was checked between every bag to make sure of total fill				
The top 67 ft of the casing was filled with 5 sack well grout 2 yds was poured and a large cap was around the surface of the casing.				

8. WELL CONSTRUCTION
 Depth Drilled 800 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
 Type perforation Refer to original log
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal Refer to original log Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started 12/15/93 19
 Date completed 12/15/93 19

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 262.5 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
 Address 625 Spice Islands Dr Suite L
Sparks, Nv 89431

Nevada contractor's license number 15291
 issued by the State Contractor's Board

Nevada driller's license number issued by the 1132
 Division of Water Resources, the on-site driller

Signed Rozenthal
 By driller performing actual drilling on site or contractor
 Date 12/21/93