

OFFICE USE ONLY  
 Log No. 43107  
 Permit No. 6-9  
 Basin 6-9  
 NOTICE OF INTENT NO. 23781

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

*STADDS*

1. OWNER Rick Banis ADDRESS AT WELL LOCATION 235 Riverdale Cr  
 MAILING ADDRESS 3110 Bramble Dr Lot 3 Block A  
Reno, Nv 89509  
 2. LOCATION NE 1/4 Sec 7 T 19 N/S R 18 E Washoe County Washoe  
 PERMIT NO. 38-693-05-09 - Riverdale # 1 Subdivision Name  
 Issued by Water Resources Parcel No. NEW

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown clay & sand volcanic rocks		0	26	26
Brown clay sands gravels		26	38	12
Green clay green gray rock		38	46	8
Brown clay brown tan & white cobbles		46	59	13
Gray clay gray green rock		59	225	166
Green & gray clay with gray & white rock		225	352	127
Green volcanic rock some fractures gray clay		352	410	58
Green fractured rock		410	519	109
T.D. 519 ft				

8. WELL CONSTRUCTION  
 Depth Drilled 519 Feet Depth Cased 519 Feet  
 HOLE DIAMETER (BIT SIZE)  

From	To
10 5/8 Inches	79 Feet
8 1/2 Inches	450 Feet
6 1/4 Inches	519 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 2	450
5	9.66	.188	439	519

Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3  
 From 430 feet to 450 feet  
 From 499 feet to 519 feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 53  Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 53 feet to 470 feet

9. WATER LEVEL  
 Static water level 140 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality \_\_\_\_\_

Date started 7/30/93, 19\_\_\_\_  
 Date completed 8/4/93, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>		<u>2 1/2</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling & Well Service, Inc  
 Contractor  
 Address 625 Spice Islands Dr Suite L  
 Contractor  
Sparks, Nv 89431  
 Nevada contractor's license number 15291  
 issued by the State Contractor's Board  
 Nevada driller's license number 1511  
 issued by the Division of Water Resources, the on-site driller  
 Signed Roger M. Thrall  
 By driller performing actual drilling on site or contractor  
 Date 8/9/93