

OFFICE USE ONLY
 Log No. 43162
 Permit No. _____
 Basin. Y-100a 91

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17994

1. OWNER NORM ORCUTT/PONCIA ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 7090 Aspen Glen Road 675 Riverdale Cir.
Reno, NV 89509 Verdi, NV 89439
 2. LOCATION N8E 1/4 Sec. 7 T. 20N 19 N S R. 18 E Washoe County
 PERMIT NO. 51691 38-294-04 Lot#1 Donner Trail Riverdale Subdiv Unit 1
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Brown clay with boulders & gravel		1	14	13
Sand & gravel		14	21	7
Brown clay with boulders & gravels		21	36	15
Granite boulder		36	44	8
Gray clay		44	162	118
Gray volcanic rock		162	216	54
Soft zone(app 3 GPM)	X	216	218	2
Gray volcanic rock		218	306	88
Green granite		306	360	54
Soft fracture weathered granite		360	363	3
Green granite		363	410	47
Fracture	X	410	419	9
Green granite		419	425	6

8. WELL CONSTRUCTION
 Depth Drilled 425 Feet Depth Cased 425 Feet
 HOLE DIAMETER (BIT SIZE)

	From	To
<u>12 1/2</u> Inches	<u>0</u> Feet	<u>38</u> Feet
<u>10</u> Inches	<u>38</u> Feet	<u>100</u> Feet
<u>8 5/8</u> Inches	<u>100</u> Feet	<u>425</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>0</u>	<u>425</u>

Perforations: factory sawed slot
 Type perforation _____
 Size perforation 3/32 x 3 x 5 around
 From 218 feet to 238 feet
 From 318 feet to 338 feet
 From 358 feet to 378 feet
 From 398 feet to 418 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 100
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100 feet to 425 feet

9. WATER LEVEL
 Static water level 69 feet below land surface
 Artesian flow 14 G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling, Inc.
 Contractor
 Address P.O. Box 12370, Reno, NV 89510
 Contractor

Nevada contractor's license number 22549
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed Wayne Drilling, Inc.
 By driller performing actual drilling on site or contractor
 Date November 12, 1991

Date started 11-5-91 19____
 Date completed 11-8-91 19____

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	