

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 43165  
 Permit No. \_\_\_\_\_  
 Basin 6-91

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18823

1. OWNER SKIP HANSEN ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 610 Ribin Street 406 Hunken Circle  
Reno, NV 89509 Verdi, NV 89439  
 2. LOCATION NE 1/4 SW 1/4 Sec 18 T. 19N N/S R. 18 E Washoe County  
 PERMIT NO. 038-082-03 Verdi Area  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil with some boulders		0	3	3
Brown clay with boulders & gravels		3	16	13
Light brown clay with gravels		16	48	32
Brown clay with boulders & gravels		48	68	20
Granite boulder		68	69	1
Gray clay		69	183	114
Dark brown clay		183	215	32
Soft zone	X	215	220	5
Dark brown clay		220	230	10
Soft zone	X	230	232	2
Dark brown clay		232	240	8
Green clay		240	243	3
Soft zone	X	243	245	2
Green clay		245	250	5

8. WELL CONSTRUCTION  
 Depth Drilled 250 Feet Depth Cased 250 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 50 Feet  
8 5/8 Inches 50 Feet 250 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	250

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 205 feet to 245 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 250 feet

9. WATER LEVEL  
 Static water level 104 feet below land surface  
 Artesian flow 20 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling, Inc. Contractor  
 Address P.O. Box 12370, Reno, NV 89510 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed [Signature]  
 by driller performing actual drilling on site or contractor  
 Date November 18, 1991

Date started 11-13-91, 19\_\_\_\_  
 Date completed 11-14-91, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	