

OFFICE USE ONLY

Log No. 40094
 Permit No. _____
 Basin 92 A

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23798

1. OWNER Jack Bissell / GeneBryan ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 190 Heritage Dr 10175 Crockett Dr
Reno, Nv 89433 Lot 14 Block 3

2. LOCATION SW 1/4 NE 1/4 Sec. 25 T. 21 N/S R. 18 E Washoe County
 PERMIT NO. 086-173-03 - Silver Knolls Estates Unit # 3
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
D. G Sands		0	2	2
Brown clay with traces of sands		2	18	16
Coarse sands & gravels with tan clay		18	45	27
Coarse sands & gravels		45	55	10
sand gravels & tan clay zones		55	75	20
sands gravels with green gray clay		75	105	30
coarse sands & gravels with small clay zones		105	132	27
Sticky tan clay		132	141	9
T.D. 141 ft				

8. WELL CONSTRUCTION
 Depth Drilled 141 Feet Depth Cased 141 Feet

HOLE DIAMETER (BIT SIZE)
 From 11 Inches To 0 Feet 141 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	141

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 101 feet to 121 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 51 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 51 feet to 141 feet

Date started 11/4/93, 19_____
 Date completed 11/5/93, 19_____
 7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		1

9. WATER LEVEL
 Static water level 90 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
Contractor
 Address 625 Spice Islands Dr Suite L
Contractor
Sparks, Nv 89431

Nevada contractor's license number 15291
 issued by the State Contractor's Board

Nevada driller's license number issued by the 1511
 Division of Water Resources, the on-site driller

Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 11/9/93