WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43168
Permit No.
Basin 7-92 A

NOTICE OF INTENT NO. 21669

1. OWNER RON BODNER
MAILING ADDRESS 4350 Del Paso Drive, Reno, NV 89502
ADDRESS AT WELL LOCATION 10400 Silver Spur, Reno, NV 89506

2. LOCATION SW ¼ NE ¼ Sec. 26 T. 21N N/S R. 18 E. Washoe County
PERMIT NO. (Issued by Water Resources) Parcel No. 087-363-13 Subdivision Name Silver Knolls

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay		1	6	5
Green clay		6	41	35
Gray clay		41	73	32
Soft zone (NO WATER)		73	76	3
Gray clay		76	99	23
Soft zone	X	99	103	4
Gray clay		103	138	35
Soft zone	X	138	142	4
Gray clay		142	150	8

'93 DEC 13 P2:22 STATE ENGINEER

Date started 12-6-93, 19
Date completed 12-7-93, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	150 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	150

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 150 feet

9. WATER LEVEL
Static water level 82 feet below land surface
Artesian flow 25 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date December 9, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627