WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43166
Permit No.
Basin 92 A

NOTICE OF INTENT NO. 23369

1. OWNER DAVID NELSON & NANCY BURBANK
MAILING ADDRESS 5325 Slope Drive
Sun Valley, NV 89433

ADDRESS AT WELL LOCATION 1280 ~~Lot 41~~ Goldstone Road
Reno, NV 89506

2. LOCATION NW SE ¼ ~~SW~~ ¼ Sec. 24 T 22N N/S R. 18 E Washoe County
PERMIT NO. (Issued by Water Resources) 079-362-19 (Parcel No.) Red Rock Estates #41 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay		1	9	8
Sandy brown clay		9	18	9
Green clay		18	91	73
Soft zone (NO WATER)		91	92	1
Green clay		92	176	84
Gray clay		176	290	114
Green weathered granite		290	360	70
Green clay		360	460	100
Weathered granite		460	465	5
Fracture	X	465	495	30
Red to pink hard granite		495	500	5

'93 NOV 29 P1:53 STATE ENGINEER

Date started 11-15-93, 19
Date completed 11-18-93, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	500 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	500

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 460 feet to 500 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 500 feet

9. WATER LEVEL
Static water level 375 feet below land surface
Artesian flow 30 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510

Nevada contractor's license number issued by the State Contractor's Board 22549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed [signature] (By driller performing actual drilling on site or contractor)
Date November 24, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627