WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43T76
Permit No.
Basin 7-4-92b

NOTICE OF INTENT NO. 20710

1. OWNER CHARLES & SHAWNNA JONES
MAILING ADDRESS 1485 G Street, Sparks, NV 89431
ADDRESS AT WELL LOCATION Red Pine, Reno, NV 89506

2. LOCATION NW ¼ NW ¼ Sec. 26 T. 21N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 080-281-04 (Parcel No.) Lemmon Valley (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay		1	11	10
Green sandy clay		11	17	6
Brown clay		17	33	16
Fine brown sand		33	34	1
Brown clay		34	71	37
Granite sands	X	71	77	6
Brown clay		77	119	42
Brown sandy clay		119	122	3
Coarse sands	X	122	141	19
Brown sandy clay		141	145	4

'93 DEC 29 AM 9:21 STATE ENGINEER

Date started 12-16-93, 19
Date completed 12-17-93, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 145 Feet Depth Cased 145 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	145 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	145

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 145 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow 20 G.P.M. P.S.I.
Water temperature cold °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date December 26, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627