

RW-2

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 45194
Permit No. B-101
Basin I
NOTICE OF INTENT NO. 19250

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER NAS FALLON ADDRESS AT WELL LOCATION _____
MAILING ADDRESS _____
2. LOCATION NAS FALLON, NEVADA NAS FALLON, NEVADA
NE 1/4 NW 1/4 Sec. 15 T. 18 N. R. 29 E. B. CHURCHILL County
PERMIT NO. M/D-200-B Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
4. *SEE BOTTOM OF LOG PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock
5. WELL TYPE Cable Rotary RVC Air Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SILTY SAND</u>		<u>0</u>	<u>1.5</u>	<u>1.5</u>
<u>GRAVEL</u>		<u>1.5</u>	<u>2.0</u>	<u>.5</u>
<u>SANDY SILT</u>		<u>2.0</u>	<u>8.0</u>	<u>6.0</u>
<u>SILT</u>		<u>8.0</u>	<u>10.5</u>	<u>2.5</u>
<u>SILTY SAND</u>		<u>10.5</u>	<u>14.5</u>	<u>4.0</u>
<u>SILT</u>		<u>14.5</u>	<u>16.0</u>	<u>1.5</u>

94 JAN -6 AUG 53
STATE ENGINEERS

8. WELL CONSTRUCTION
Depth Drilled 16.0 Feet Depth Cased 14.0 Feet
HOLE DIAMETER (BIT SIZE)
From 18 Inches To 16.0 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.625</u>	<u>3.7</u>	<u>.28</u>	<u>3.0</u>	<u>4.0</u>
<u>6.625</u>	<u>3.45</u>	<u>.28</u>	<u>3.0</u>	<u>4.0</u>

Perforations:
Type perforation VEE WIRE WRAPPED (JOHANSON)
Size perforation .020
From 4.0 feet to 14.0 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
Depth of Seal 3.5
Placement Method: Pumped Poured
Gravel Packed: Yes No
From 3.5 feet to 16.0 feet

Date started 7/14 1993
Date completed 7/14 1993

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL
Static water level 7.0 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality HIGH OVA (P.P.M.) 1000 5.0

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name P.C. Exploration Contractor
Address 1125W. 650 N. CENTERVILLE, UT. 84014 Contractor
Nevada contractor's license number issued by the State Contractor's Board _____
Nevada driller's license number issued by the Division of Water Resources the on-site driller M-1815
Signed Randy
By driller performing actual drilling on site or contractor
Date 11-29-93