VT-2

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43[illegible]7
Permit No.
Basin 8-101

NOTICE OF INTENT NO. 19251

1. OWNER NAS FALLON
MAILING ADDRESS NAS FALLON, NEVADA
ADDRESS AT WELL LOCATION NAS FALLON, NEVADA

2. LOCATION NE ¼ NW ¼ Sec. 15 T 18 N/S R 29 E ~~BA~~ CHURCHILL County
PERMIT NO. M/O-200-B
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE *SEE BOTTOM OF LOG
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| SILTY SAND | | 0 | 3.0 | 3.0 |
| CLAYEY SAND | | 3.0 | 5.0 | 2.0 |
| SILTY SAND | | 5.0 | 8.5 | 3.5 |
| CLAYEY SILT | | 8.5 | 10.5 | 2.0 |

'94 JAN -6 A10:53
STATE ENGINEER

WELL TO BE USED FOR VAPOR OBSERVATION

Date started 6/2, 1993
Date completed 6/2, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 10.5 Feet Depth Cased 9.0 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 8 Inches | 0 Feet | 10.5 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2.375 | .170 | .308 | 3.0 AGS | 4.0 |

Perforations:
Type perforation MACHINE SLOTTED (MONOFLEX)
Size perforation .020
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 3.5
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 3.5 feet to 10.5 feet

9. WATER LEVEL
Static water level 6.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name P.C. Exploration
Contractor
Address 1125 W. 650 N.
Contractor
CENTERVILLE, UT 84014
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1815
Signed [signature]
By driller performing actual drilling on site or contractor
Date 11-29-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627