WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43202
Permit No.
Basin 101

NOTICE OF INTENT NO. 23442

1. OWNER Cliff Weston
MAILING ADDRESS P.O. Box 602
Silver Springs, NV 89429

ADDRESS AT WELL LOCATION
16000 Lahontan Dam Road
Fallon, NV 89406

2. LOCATION S2 ¼ SE ¼ Sec. 35 T 19 N/S R 26 E Churchill County

PERMIT NO. (Issued by Water Resources) | Parcel No. 7-071-39 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Coarse Brown Sand		0	22	22
Fine Brown Sand		22	30	8
Coarse Brown Sand		30	35	5
Gravel & Boulders		35	72	37
Brown Clay		72	78	6
Gravel		78	90	12
Brown Clay		90	118	28
Gravel	X	118	128	10

Date started November 4, 19 93
Date completed November 9, 19 93

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 128 Feet Depth Cased 128 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	35 Feet
8 3/4 Inches		35 Feet	128 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	123

Perforations:
Type perforation Well Screen
Size perforation .035
From 123 feet to 128 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 128 feet

9. WATER LEVEL
Static water level 47' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wayne Parsons (By driller performing actual drilling on site or contractor)

Date Dec. 8, 1993

DEC 13 P2:21 '93 STATE ENGINEER

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627